

61 Louisa Viens Drive
Dayville, CT 06241
Fax: 860-774-2689
Phone: 860-774-6814
Toll-Free: 800-334-0103

ANALYTICAL DATA REPORT


prepared for:

Hudson Public Schools
155 Apsley Street
Hudson, MA 01749
Leonard Belli

Report Number: E603P13
Project: Mulready Elementary School

Received Date: 03/28/2016

Report Date: 03/31/2016



David Dickinson
Technical Director



CT DPH #PH-0465
ME DHHS #CT0050
VA #460279

EPA #CT00008
NH ELAP #2020
VT DOH #VT11549

KY EEC #90151
NY ELAP #11549

MA DEP #M-CT008
PA DEP #68-04413

MD #349
RI DOH #LAO00346

TN #04903



101-000000496909



61 Louisa Viens Drive
Dayville, CT 06241
Fax: 860-774-2689
Phone: 860-774-6814
Toll-Free: 800-334-0103

Report No: E603P13
Client: Hudson Water District
Project: Mulready Elementary School

CASE NARRATIVE / METHOD CONFORMANCE SUMMARY

The results presented in this report relate only to the samples received.

This report is incomplete unless all pages indicated in the pagination at the bottom of the page are included, along with a copy of the chain of custody and any subcontracted analyses reports, if applicable, for the sample(s) in this report. Subcontractor results are identified by 'SUB' next to the analysis.

Microbac Laboratories, Inc. received 11 samples from Hudson Water District on 03/28/2016. The samples were analyzed for the following list of analyses in accordance with MA DEP regulations unless otherwise indicated:

Lead by 200.8 DW/WW
200.8[3000]

Non-Conformances:
Work Order:

None

Sample:

None

Analysis:

None

Microbac Laboratories, Inc.

Analytical Data Report

Report No: E603P13
 Date Received: 03/28/2016 14:42

Customer: Hudson Water District
 Project: Mulready Elementary School

<u>Parameter</u>	<u>Result</u>	<u>DL</u>	<u>Units</u>	<u>Completed</u>	<u>By</u>	<u>Dilution</u>
(1) SB09 - First Draw						
Date Collected: 03/25/2016 08:58		Matrix: Aqueous				
Metals by ICP/MS 200.8						
Lead	0.0015	0.0010	mg/L	03/30/2016 19:33	NS	
(2) DF01 - First Draw						
Date Collected: 03/25/2016 08:12		Matrix: Aqueous				
Metals by ICP/MS 200.8						
Lead	0.0012	0.0010	mg/L	03/30/2016 19:44	NS	
(3) DF02 - First Draw						
Date Collected: 03/25/2016 08:39		Matrix: Aqueous				
Metals by ICP/MS 200.8						
Lead	ND	0.0010	mg/L	03/30/2016 19:48	NS	
(4) DF03 - First Draw						
Date Collected: 03/25/2016 08:45		Matrix: Aqueous				
Metals by ICP/MS 200.8						
Lead	ND	0.0010	mg/L	03/30/2016 19:51	NS	
(5) DF04 - First Draw						
Date Collected: 03/25/2016 08:47		Matrix: Aqueous				
Metals by ICP/MS 200.8						
Lead	0.0016	0.0010	mg/L	03/30/2016 19:55	NS	
(6) DF05 - First Draw						
Date Collected: 03/25/2016 08:55		Matrix: Aqueous				
Metals by ICP/MS 200.8						
Lead	0.0018	0.0010	mg/L	03/30/2016 19:59	NS	
(7) SB03 - First Draw						
Date Collected: 03/25/2016 09:03		Matrix: Aqueous				
Metals by ICP/MS 200.8						
Lead	0.0052	0.0010	mg/L	03/30/2016 20:10	NS	
(8) S02 - First Draw						
Date Collected: 03/25/2016 08:50		Matrix: Aqueous				
Metals by ICP/MS 200.8						
Lead	ND	0.0010	mg/L	03/30/2016 20:14	NS	
(9) KS01 - First Draw						
Date Collected: 03/25/2016 08:53		Matrix: Aqueous				
Metals by ICP/MS 200.8						
Lead	0.0026	0.0010	mg/L	03/30/2016 20:17	NS	

Microbac Laboratories, Inc.
Analytical Data Report

Report No: E603P13
Date Received: 03/28/2016 14:42

Customer: Hudson Water District
Project: Mulready Elementary School

<u>Parameter</u>	<u>Result</u>	<u>DL</u>	<u>Units</u>	<u>Completed</u>	<u>By</u>	<u>Dilution</u>
(10) K02 - First Draw						
Date Collected: 03/25/2016 08:52		Matrix: Aqueous				
Metals by ICP/MS 200.8						
Lead	ND	0.0010	mg/L	03/30/2016 20:21	NS	
(11) SB06 - First Draw						
Date Collected: 03/25/2016 09:00		Matrix: Aqueous				
Metals by ICP/MS 200.8						
Lead	0.0012	0.0010	mg/L	03/30/2016 20:25	NS	



Microbac Laboratories, Inc.
61 Louisa Viens Drive
Dayville, CT 06241

Chain of Custody

www.microbac.com
800-334-0103

page _____ of _____

Lab WO #: EG03P13
Project Manager: LD

Copy of Report To

Billing Information

Project Information

CUSTOMER: Hudson Public Schools

BILL TO: Hudson Public Schools

Project: Wetready Elem School

ADDRESS: 155 Apsey St
Hudson, Ma 01749

ADDRESS: 155 Apsey St
Hudson, Ma 01749

Location: 306 Cox Street

DELIVERY:

ATTN: Len Belli
PHONE: 978 562 6104

Project Mgr: L. P. Belli

IN CASE WE HAVE ANY QUESTIONS WHEN SAMPLES ARRIVE WE SHOULD CALL:

E-MAIL: lpbelli@hudson.k12.ma.us

E-MAIL: lpbelli@hudson.k12.ma.us

E-MAIL:

PHONE: 508 626 6104 FAX:

PURCHASE ORDER #:

PHONE:

FAX:

Sample Identification	Date Collected	Time Collected	Sample Matrix	Sample Type		Bottle Qty	Analysis				Preservatives							
				Composite	Grab						NON-PRES	HCL	HNO ₃	H ₂ SO ₄	OTHER			
<u>SB09</u> <u>First Draw Lead</u>		<u>8:58</u>																
<u>DF01</u>	<u>3-25-16</u>	<u>08:30</u>	<u>8:12</u>															
<u>DF02</u>		<u>8:39</u>																
<u>DF03</u>		<u>8:45</u>																
<u>DF04</u>		<u>8:47</u>																
<u>DF05</u>		<u>8:55</u>																
<u>SB03</u>		<u>9:03</u>																
<u>S02</u>		<u>8:50</u>																
<u>KS01</u>		<u>8:53</u>																
<u>K02</u>		<u>8:52</u>																
<u>SB06</u>		<u>9:00</u>																

CUSTODY TRANSFER	DATE	TIME	TURNAROUND TIME REQUESTED (select):	<u>Standard</u>	RUSH _____ Day
SAMPLER: <u>Brad Parker</u>	<u>3-25-16</u>	<u>08:30</u>	EXPEDITED SERVICE MAY BE SUBJECT TO SURCHARGE		
RECEIVED:			Circle Delivery Method:	<u>E-MAIL</u>	HARD COPY _____ OTHER _____
RELINQUISHED: <u>to Microbac</u>	<u>3-28-16</u>	<u>11:30</u>	COMMENTS:		
RECEIVED: <u>J. Street</u>	<u>3-28-16</u>	<u>11:30</u>	PRESERVATIVE VERIFIED Initials <u>JL</u>		
RELINQUISHED: <u>J. Street</u>	<u>3-28-16</u>	<u>14:42</u>	CONDITIONS UPON RECEIPT: (CHECK ONE)		
RECEIVED:	<u>3-28-16</u>	<u>1442</u>	COOLED <input checked="" type="checkbox"/>	AMBIENT <input type="checkbox"/>	°C Upon receipt at lab

10 bottles

3.3 ©